

## **Specifications for roof, gutter, and downspout heat tape at RCV**

- A building permit is required from Park City Municipal
- Must use PMA approved contractors for gutters and heat tape
- Owners and contractors must contact PMA for specific requirements and documents. A refundable deposit of \$750.00 is required along with all proper insurance, licensing, paperwork, etc.
- Gutter and downspout installed with color match approved by PMA
- A minimum of 100 feet of Raychem h612 self regulating heat tape or equivalent approved by PMA (installed to manufacturers recommendations)
- H908 Protection Device or 30mA Ground Fault Protection for Equipment Circuit Breaker for each run of tape
- Raychem H913 load releasing attachment clips or equivalent approved by PMA
- One Raychem H915 downspout hanger installed at the top of the downspout or equivalent approved by PMA
- Sub panel and breaker disconnect OUTSIDE the residence for access
- Dedicated 20 amp circuit that comes from the right home owners electrical service for each run of tape
- Inspection by Park City Municipal Corp. Building Department
- A minimum of 1 year parts and workmanship warranty